

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CL0214

Product Identification No.
 Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) EG-Gasgeräterichtlinie (2009/142/EG)
Distributor <i>Vertreiber</i>	BAXI Calefacción, S.L.U. Salvador Espriu, 9, E-08908 L'Hospitalet de Llobregat-Barcelona
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing combi water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger
Model <i>Modell</i>	PLATINUM COMPACT...; NEODENS PLUS...
Countries of Destination <i>Bestimmungsländer</i>	AL, AT, BE, BG, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, MK, NL, NO, PL, PT, RO, SE, SI, SK, TR
Test Reports <i>Prüfberichte</i>	supplement test: 14/017/3204/995 from 31.01.2014 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 483 (01.06.2000) DIN EN 677 (01.08.1998) DIN EN 625 (01.10.1995)
File Number <i>Aktenzeichen</i>	14-0068-GEA



12.02.2014 Rie C-1/2
 Date, issued by: Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



DVGW CERT GmbH
 Zertifizierungsstelle
 Josef-Wirmer-Str. 1-3
 53123 Bonn
 Tel. +49 228 91 88 - 888
 Fax +49 228 91 88 - 993
 www.dvgw-cert.com
 info@dvgw-cert.com

Electrical Data 230 V AC, 50 Hz, IPX5D
Elektrische Daten

Appliance Categories <i>Gerätekatogorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	DK	
I3P	37 mbar	BE	
II2E LwLs3P	20,20,13, 37 mbar	PL	
II2E3P	20, 37 mbar	LU	
II2ELL3P	20, 50 mbar	DE	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	AT, EE, FI, LT, LV, NO, RO, SE, SI	
II2H3P	20, 37 mbar	CZ, ES, GB, GR, HR, IE, IT, PT, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 37 mbar	HU	
II2L3P	25, 37 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
PLATINUM COMPACT 24/24 F; PLATINUM COMPACT 24/24 F ECO; NEODENS PLUS 24/24 F	nominal heat output: 3,4...20,0 kW nominal heat input (Hi): 3,5...20,6 (drinking water: ...24,7) kW	
PLATINUM COMPACT 28/28 F; PLATINUM COMPACT 28/28 F ECO; NEODENS PLUS 28/28 F	nominal heat output: 3,8...24,0 kW nominal heat input (Hi): 3,9...24,7 (drinking water: ...28,9) kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types B23, B33, C13, C33, C43, C53, C63, C83: according to "installation manual PLATINUM COMPACT..."
 respectively "installation manual NEODENS PLUS..."

Additionally tested appliance categories, supply pressures and countries of destination:

CY: II2H3P (20, 30 mbar)

AL, BG, MK: II2H3P (20, 37 mbar)

In Albania and in Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania respectively Macedonia.

EC type examination certificate
EG-Baumusterprüfbescheinigung

CE-0085CL0214

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) EG-Wirkungsgradrichtlinie (92/42/EWG)
Distributor <i>Vertreiber</i>	BAXI Calefacción, S.L.U. Salvador Espriu, 9, E-08908 L'Hospitalet de Llobregat-Barcelona
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing combi water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger
Model <i>Modell</i>	PLATINUM COMPACT...; NEODENS PLUS...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: 14/017/3204/995 from 31.01.2014 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	14-0068-GWA



70028-04-A-DE

12.02.2014 Rie C-1/2


Date, issued by, Sheet, Head of Certification Body
 Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH - recognized by the German Institute for Building Technology (DIBt) and notified at the European Commission as certification body for the EC Boiler Efficiency Directive

DVGW CERT GmbH - vom Deutschen Institut für Bautechnik (DIBt) nach dem Bauproduktengesetz anerkannte und bei der Europäischen Kommission benannte Zertifizierungsstelle für die EG-Heizkessel-Wirkungsgradrichtlinie

DIBt
ZP 42

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Energy Labelling Energieeffizienzkennzeichnung
PLATINUM COMPACT 24/24 F; PLATINUM COMPACT 24/24 F ECO; NEODENS PLUS 24/24 F	nominal heat output: 3,4...20,0 kW nominal heat input (Hi): 3,5...20,6 (drinking water: ...24,7) kW	****
PLATINUM COMPACT 28/28 F; PLATINUM COMPACT 28/28 F ECO; NEODENS PLUS 28/28 F	nominal heat output: 3,8...24,0 kW nominal heat input (Hi): 3,9...24,7 (drinking water: ...28,9) kW	****

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

The energy labelling can be used according to the actual regulations of the country of destination for the individual types. The above listed model was certified under the Product-Identnumber CE-0085CL0214 according to the Gas Appliance Directive (2009/142/EC).